



Figure 2.6-24 Inspection Opening No. 5

2.6.2.6 Inspection Opening No. 6. The sixth inspection opening was made at the intersection of perpendicular ridges in the existing roofing membrane. The existing construction at this location generally consists of the following (from top to bottom):

- a. Approximately four layers of elastomeric coating (includes base, intermediate, and several finish coats).
- b. Approximately 2-inch thick layer of cementitious fill (lightweight insulating concrete). Joints in the fill are shown in Figure 2.6-25.
- c. Four-ply built-up roofing (asphalt).
- d. Three-inch thick rigid foamglass insulation.
- e. Asphalt mopping layer.
- f. Approximately 1/2-inch thick layer (tapered) All-Weather Crete asphalt/perlite fill (wet).