

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE		PAGE	OF	PAGES
					1		3
2. AMENDMENT/MODIFICATION NO. 09		3. EFFECTIVE DATE 06/08/09		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY National Aeronautics and Space Administration Ames Research Center Moffett Field, CA 94035-1000		7. ADMINISTERED BY (If other than Item 6)		CODE			
8. NAME AND ADDRESS OF CONTRACTOR (No. Street, county, State and ZIP Code)				(A)		9A. AMENDMENT OF SOLICITATION NO. NNA09273580R	
				XX		9B. DATED (SEE ITEM 11) 05/08/09	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

## 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATA SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and data specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

## 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(4)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER: Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Subj: Collaborative Support Facility, Building N232 at NASA Ames Research Center, Moffett Field, CA

Changes and/or alterations to the solicitation, specification, and drawings are issued herewith and made a part of the solicitation.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		BY (Signature of Contracting Officer)	

**ATTACHMENT J-1  
SPECIFICATION NO. 60048683**

**Specification Section 232113.33 – Ground-Loop Heat-Pump Piping:**

In paragraph 3.5C, delete subparagraphs 9 and 12.

**Specification Section 232113.33 – Ground-Loop Heat-Pump Piping:**

Add paragraph 3.6 Disposal as follows:

**“3.6 DISPOSAL**

Remove waste material, trash and debris and legally dispose of them off Government property. The Contractor shall collect all drilling spoils, fluids, and artesian flow liquids and transport them to a designated disposal site on Government property, within 2 miles of the well field. Stockpile or spread as directed by the Contracting Officer.”

**Specification Section 077200 – Roof Accessories:**

Amendment #8 had an error in the change to this specification section. The correct change should have been:

Delete paragraph 3.2E, including subparagraphs 1 and 2.

**Specification Section 084413 – Glazed Aluminum Curtain Walls**

In paragraph 2.10A, delete subparagraph 1, and replace it with the following:

“1. Exposed surfaces shall receive specified finish with no mill finish aluminum exposed unless otherwise indicated.”

**Specification Section 142400 – Hydraulic Elevators**

Delete paragraphs 1.2C and 1.2D.

## **DRAWINGS FOR THE COLLABORATIVE SUPPORT FACILITY**

**Drawing A105** – Under the heading Exterior Finish/Color Legend, change the designation AL-1:

Delete “Smoke Grey, YL204U”  
Insert “Clear Anodic Finish per specifications”.

**Drawing A701** – In Detail 9/S701, the keynote callout pointing to a dashed line under the slab on grade shall be changed to from 7.11 to 3.3.

**Drawing E121** - The model number for light fixture H1 shall be changed as follows:  
Catalog Number: 85022.023

Description: Cylinder Facade luminaire direct lighting for low-voltage halogen lamps

MRC16 50W 12V GU5.3 10° - First Floor  
MRC16 50W 12V GU5.3 36° - Second Floor

## **QUESTIONS AND ANSWERS**

1. **Question:** Is the contractor responsible for builders risk insurance or not?  
**Answer:** The contractor is only required to obtain the insurance coverage in NFS 1852.228-75, Minimum Insurance Coverage. The contractor may obtain builders risk insurance at his own discretion, but since this is a firm-fixed-price contract, the insurance costs are NOT separately reimbursed.