



June 22, 2009

Subject: Project Approval Signatures:  
**CONSTRUCT CONSOLIDATED INFORMATION TECHNOLOGY  
CENTER: PRE BID ADDENDUM #1**

I have reviewed the attached Pre-bid addendum package for the subject construction project, and find to the best of my knowledge, that they meet current program requirements and comply with current codes.

Chief, Facility Engineering & Asset Management Office

6/24/09

Date

Project Manager (PM)

6/22/09

Date

DEPUTY Chief, Protective Services Office

6/24/09

Date

Project Requestor/Customer

6/24/09

Date

Chief, Safety, Health & Environmental Office

6/24/09

Date

Chief Information Office

6/24/09

Date

**Pre-Bid Addendum #1 for  
Construct Consolidated Information Technology Center**

At NASA Dryden Flight Research Center, Edwards AFB, CA 93523-0273

6/22/2009

The following changes shall be made to the original solicitation documents:

Sheet #C-4 – Utility Plan

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet # A-3.0 – First Floor RCP

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet. Note that the 48”perforated aluminum overhang is called out.

Sheet # A-3.1- Second Floor RCP

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet. Note that the 48”perforated aluminum overhang is called out.

Sheet #A-7.0- Door Schedule First Floor

1. Add to “SCIF DOOR NOTE”: “‘Krieger acoustical door’ of Pico Rivera, CA. Model #NC3-16-8550 or approved equal”

Sheet #M-10- Mechanical Details

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet #E-3- Electrical First Floor Power Plan

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet #E-8- Single Line Diagram

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet #E-9- Single Line Diagram

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet #E-10- Substation #26 Electrical Floor Plan

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet #E-16- Electrical Panel Schedules

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Sheet #FP1.0- Fire Protection Plan

1. Replace entire Sheet with Pre Bid Addendum #1 Sheet.

Spec Section 00 01 15- List of Drawings

1. **Replace** 1.1 SUMMARY with the following: “This section lists the drawings for the project pursuant to contract clause “FAR 52.236-21, Specifications and Drawings for Construction”

Spec Section 01 11 00.00 40 – Summary of Work

1. **Replace** 1.1 SUMMARY with the following: “Provide all materials, equipment and labor to Construct Consolidated Information Technology Center as shown on the attached Drawings and more particularly specified herein, at NASA Dryden Flight Research Center at Edwards AFB, CA 93523-0273. The project includes demolition and sitework; new two-story steel-framed concrete masonry structure; interior partitions, architectural features and finishes; plumbing and mechanical work; electrical work; and fire protection systems. The project also includes some demolition, reconstruction work, and modification of the elevator system in the existing DAF B4838. This project will be LEED-NC, Silver Certified.” b

Spec Section 01 20 00.00 20 – Price and Payment Procedures

1. **Replace** 1.4 CONTRACT MODIFICATION with the following: “ In conjunction with “FAR clause 52.243-6, Change Order Accounting,” and where actual ownership and operating costs of construction equipment cannot be determined from Contractor accounting records, the contractor shall maintain such accounts until the parties agree to an equitable adjustment for the changes ordered by the Contracting Officer or the matter is conclusively disposed of in accordance with the Disputes clause in the FAR”
2. **Add** attached NASA-DFRC Form 809-8 – Construction Contractor’s Invoice, to be used for monthly progress reporting and payment requests, to section 1.6.1- CONTENT OF INVOICE, part a.
3. In 1.7.1 OBLIGATION OF GOVERNMENT PAYMENTS, part b. **replace** with the following: “Failure to provide up to date drawings”

Spec Section 01 30 00 – Administrative Requirements

1. **Delete** paragraphs: “1.5.5.2 CITIZEN REQUIREMENTS” and “1.5.5.3 DOCUMENTS ACCEPTABLE FOR PROOF OF CITIZENSHIP”.
2. 1.6 SUPERVISION: **Revise** second sentence to read: “In addition, the Quality Control (QC) Representative shall also have fluent English communication skills.”

Spec Section 01 33 00 – Submittal Procedures

1. 1.15.2 DEVIATIONS: **Delete** “For submittals which include proposed deviations requested by Contractor, the column “variation” of ENG Form 4025 shall be checked.”

Spec Section 01 50 00- Temporary Construction Facilities and Controls

1. 3.2.8 OBSTRUCTION LIGHTING OF CRANES: **Delete** “Light construction and installation must comply with FAA AC 70/7460-1.”

Spec Section 01 57 19.00 20- Temporary Environmental Controls

1. 3.11 RELEASE/SPILLS OF OIL AND HAZARDOUS SUBSTANCES: **Replace** all “Navy” references with “NASA”