

# Ancillary AST Inspection Checklist

Instructions: Complete routine external visual inspection of ancillary ASTs (i.e., *consumptive use tanks*), diesel powered electrical generators, pad-mounted electrical transformers, and used cooking oil containers. Notify the Code SH Hazardous Materials Technician immediately if any significant deficiencies are identified.

FREQUENCY: <b>Monthly</b> - except annually for pad-mounted transformers	SITE/BLDG:	DATE:	INSPECTOR:		
	YES	NO	N/A	CAR	COMMENTS
<b>Structural Integrity</b>					
Surface free of leaks?					
Valves and gaskets free of leaks?					
Condition sound ( <i>no corrosion, pitting, etc.</i> )?					
Bolts, rivets, welds and seams intact / sound?					
Foundation intact / sound?					
Level gauges and alarms working?					
Vents unobstructed?					
<b>Attached Piping</b>					
Surface free of leaks?					
Valves and fittings free of leaks?					
Piping adequately supported?					
Pipes and supports free of corrosion?					
Buried pipes exposed?					
Out-of-service pipes capped?					
Signs / barriers present near aboveground piping?					
Localized vegetation free of distress?					
<b>Secondary Containment</b>					
Drainage valves closed and locked?					
Drainage valves free of leaks?					
Containment area free of drainable water?					
Standing water free of products / sheen?					
Debris absent?					
Containment structure intact / sound?					
<b>Security</b>					
Unit locked?					
Gates / fences intact / sound?					
Gates / fences locked?					
Starter controls locked?					
Lighting adequate?					
Signs, placards, labeling?					

NOTE:

N/A - Not Applicable

CAR - Corrective Action Required