

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF PAGES 2
2. AMENDMENT/MODIFICATION NO. Amendment Nine (9)		3. EFFECTIVE DATE 5/23/2012	4. REQUISITION/PURCHASE REQ. NO. N/A	5. PROJECT NO. (if applicable)	
6. ISSUED BY NASA Ames Research Center William E. Hale Mailstop 213-1 Moffett Field, CA 94035-0001		CODE JAC: 241-1	7. ADMINISTERED BY (if other than Item 6) William Hale (650) 604-2849		CODE JAC
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) TO ALL PROSPECTIVE OFFERORS			(X)	9A. AMENDMENT OF SOLICITATION NO. NNA1226099R	
			X	9B. DATED (SEE ITEM 11) 3/1/12	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
(X) The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers (X) is extended, () is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; Or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PALCE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT /ORDER NO. AS DESCRIBED IN ITEM 14.					
CHECK ONE	A. THIS ORDER ID ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).				
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
	D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor () is not, (X) is required to sign this document and return <u>1</u> copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible)					
a. The purpose of this amendment is to post responses to offerors' questions.					
b. Steam Vacuum System NOx Emission Reduction System Question Set 5 is attached. (Attachment 1)					
Except as provided herein, all terms and conditions of the document referenced in item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			_____ (Signature of Contracting Officer)		
NSN 7540-01-152-8070 Previous edition unusable			STANDARD FORM 30 (REV. 10-83) Prescribed by GSA FAR (48 CFR) 53.243		

Steam Vacuum System NOx Emission Reduction System
NNA1226099R
Question Set 5
May 23, 2012

RFP Reference	Question/Comment	Answer(s)
1	RFP Section L-11 Section L.11(b)(2) states that the Cover Letter is to be included in Volume I, but Section L.11(c) "Technical Acceptability (Volume I)" states that "No price data shall be included." Which is correct?	Per the instructions in Section L the Cover Letter is placed in Volume I of the proposal. Pricing Data is to be in Volume III of the proposal.
2	Drawings PG 297 (Section 44 10 00, Page 11, section 1.8.1 paragraph C – top of page) states that "the new NOx system must integrate with the existing NOx equipment". Please confirm this integration is not required, merely the operation of the existing cannot be interrupted per the drawings.	What the comment means is the current system cannot be interrupted until the new system is fully functional per the drawings.