

Construction of the Flight Projects Building
Solicitation No. NNG13412656E
Questions and Responses
December 7, 2012

1. *Can HDPE jacket pipe be used in underground heat distribution system be used?*

Response: HDPE jacket may be used, PVC and polyethylene jackets shall not be used in underground heat distribution system.

POTENTIAL BIDDERS

The cut-off date to submit questions to the Contracting Officer was Friday November 30, 2012. This allowed the Government time to ensure that all questions have been answered and posted through the Government Websites (NASA/FedBizOps) in a timely manner before the bid opening date of December 7, 2012.

[End of Questions/Responses]