

Multiple Award Construction Contract (MACC) II

Final RFP-Questions and Answers Set 3

NNA12450885R-PFM

June 5, 2013

RFP Section, Paragraph and Page	Question/Comments	Government Response
10. Attachment J-8 Drawings for Sample Task 1 REDS, page 12	Drawing E22 building N223 shows the addition of three light sensors, one in 1200A Breaker enclosure, one in Panel MS and one in Panel MPP. The panels are located in room 132. Is there a specification for the Sensor?	Yes, there is a specification for the sensor. The specification for the AFD system, is in section 26 05 73.00 40, page 12.
11. Attachment J-8 Drawings for Sample Task 1 REDS	Is there a plan available to show the distance between VCB 492 and the Panels in room 132?	The distance between the VCB 492 and panels in room 132 is approximately 30 feet.
12. Attachment J-8 Drawings for Sample Task 1 REDS	Drawing E30 N227D shows the removal of existing cable from T038 in building N227D to VCB088 in building N227, room 150. Are there plans available to determine the distance involved?	The distance between the VCB088 and T038 is approximately 350 feet.
13. General Question	Do we need a badge to enter your facility?	Yes, any offeror hand delivering their proposals will need a badge to enter the facility. Please email Patricia Finnell-Mendoza at <a href="mailto:patricia.f.mendoza@nasa.gov">patricia.f.mendoza@nasa.gov</a> to request a badge. Please provide in the email the person's name (first and Last), Company name, and if they are a US Citizen or not. A valid driver's license with picture identification will be required before being badged and allowed access to the facility.