

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES 1   5
2. AMENDMENT/MODIFICATION NO. 002	3. EFFECTIVE DATE See Block 16C	4. REQUISITION/PURCHASE REQ. NO. 4200457725	5. PROJECT NO. (If applicable) PCN 98986	
6. ISSUED BY NASA/Kennedy Space Center Office of Procurement, OP-ES Andrew Dennis Kennedy Space Center, FL 32899		7. ADMINISTERED BY (If other than Item 6)		

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. NNK13457725R
	<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) February 1, 2013
	<input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NO.
	<input type="checkbox"/> 10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to release the 100% Design Specifications and Drawings, add reference drawings, establish the closing submission date for Part 2 (Price Volume), reopen a question submittal period, document answers provided to questions received, and update Attachment J.1.J Government Furnished Equipment/Property/Material.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Andrew S. Dennis Contracting Officer
15B. CONTRACTOR/OFFEROR	16B. UNITED STATES OF AMERICA
15C. DATE SIGNED	16C. DATE SIGNED 3/7/2013
(Signature of person authorized to sign)	(Signature of Contracting Officer)

The Government's responses to questions submitted on the Solicitation are contained within this amendment. The responses to questions shall not be construed as altering the requirements of the RFP except as specifically revised in this amendment.

**1. A question received and the associated Government response is shown below:**

18. REFERENCE: ED102, ED103, ED901: At the site visit it was noted that there are conduits that pass through the "hatched" area of the drawing that are fed from and serve equipment outside the hatched areas. Conduits are mounted to overhead beams, cable tray supports and walls. The source and loads are not indicated on the drawing. Please provide information on these items if they are to be removed/replaced/re-worked per flag note 2 on the referenced drawings. (quantity, conduit size, cable type, source and load locations.)

**RESPONSE:**

It is the responsibility of the contractor to determine the source/load for each circuit/conduit to be modified. The reference drawings 242M2700002, 242M2700002TRO6951, 242M2700002TRO6962, and 242M2700002TRO5887 provides fed from data and quantity and type of cables, conduit sizes, source and load locations for the fire alarm system, ODMS system and power systems.

In most cases, the wire/cable will need to be disconnected at the load and pulled back to the conduit section required to be reworked then reinstalled into the new conduit. In most cases the conduit should be able to be reinstalled without requiring the replacement of wire/cable. The extent of conduit/cables to be modified is at the contractor's discretion. Note: the seal-offs have not been poured.

The existing cable tray should not be required to be modified except for what is noted on ED106 and ED107. The cable tray supports for cable trays for PB2-2 and DB2-2 will be required to be reworked from ceiling mount to wall mount on the side closest to column line G.

**2. The 100% Drawings Package and Specification are released. In addition, Reference Drawings 79K06110, 242M2700002TRO6951, 242M2700002TRO6962 and 242M2700002TRO5887 are added to the Solicitation. The drawings package, specification, and reference drawings are classified as "Sensitive But Unclassified" (SBU) information and contain Export Controlled data. Therefore, all offerors must explicitly request access to those documents through <https://www.fbo.gov>. Instructions for properly registering and requesting access can be found under Section 4.5 through 4.8 of the FBO Vendor Guide at**

**[https://www.fbo.gov/downloads/FBO\\_Vendor\\_Guide\\_v1.7.pdf](https://www.fbo.gov/downloads/FBO_Vendor_Guide_v1.7.pdf). These drawings and specifications are required for your proposal preparation and must be requested by you.**

**Once properly registered, the documents are located at <https://www.fbo.gov/fedteds/NNK13457725R2>**

**3. Solicitation, Section C – Description/Specifications, Clause C.1 Specification/Statement of Work is revised to read as follows:**

The Contractor shall provide the item or services specified in Section B.2 in accordance with the following:

**Attachment J1:**

**Drawings**

Number: K0000135925  
Title: Mobile Launcher Modifications for SLS  
Date: 100%, February 28, 2013  
No. of Sheets: 308

**Specifications**

Number: K0000135926-SPC  
Title: Mobile Launcher Modifications for SLS  
Date: 100%, February 28, 2013  
No. of Sheets: 497

**Drawings (For Reference Only)**

**CLV Mobile Launcher Launch Mount Stand Drawings (For Reference only)**

Number: 242M0300005  
Title: CLV Mobile Launcher Launch Mount Transporter & Support Stand  
Date: 4/10/2008  
No. of Sheets: 6

**CLV Mobile Launcher Launch Mount Structure Drawings (For Reference only)**

Number: 242M0300004  
Title: CLV Mobile Launcher Launch Mount Structure  
Date: 2/13/2009  
No. of Sheets: 50

NNK13457725R  
Amendment 2

**CLV Mobile Launcher Structure Drawings (For Reference only)**

Number: 242M2700002  
Title: CLV Mobile Launcher Structure  
Date: 5/15/2011  
No. of Sheets: 449

**Drawings (For Reference Only)**

Number: 79K06110  
Title: Procedure for MI Cable Terminations  
Date: October 29, 1980  
No. of Sheets: 12

**Drawings (For Reference Only)**

Number: 242M2700002TRO6951  
Title: Fire Alarm Module Schematic Drawings (Revision 1)  
Date: October 10, 2010  
No. of Sheets: 41

**Drawings (For Reference Only)**

Number: 242M2700002TRO6962  
Title: Fire Alarm As-Built Drawings (Revision 1)  
Date: October 20, 2010  
No. of Sheets: 17

**Drawings (For Reference Only)**

Number: 242M2700002TRO5887  
Title: ODMS Record Drawings  
Date: February 9, 2010  
No. of Sheets: 62

**4. Solicitation, Section J – List of Documents, Exhibits and Other Attachments, Clause J.1 List of Attachments, Attachment J.1.E is revised to add the following reference drawings:**

**Drawings (For Reference Only)**

Number: 79K06110  
Title: Procedure for MI Cable Terminations  
Date: October 29, 1980  
No. of Sheets: 12

Drawings (For Reference Only)

Number: 242M2700002TRO6951  
Title: Fire Alarm Module Schematic Drawings (Revision 1)  
Date: October 10, 2010  
No. of Sheets: 41

Drawings (For Reference Only)

Number: 242M2700002TRO6962  
Title: Fire Alarm As-Built Drawings (Revision 1)  
Date: October 20, 2010  
No. of Sheets: 17

Drawings (For Reference Only)

Number: 242M2700002TRO5887  
Title: ODMS Record Drawings  
Date: February 9, 2010  
No. of Sheets: 62

**5. Solicitation, Section L – Instructions, Conditions, and Notices to Bidders, L.17 Communications Regarding this Solicitation, Paragraph (b) is revised as following to reopen the question and comment period:**

(b) Questions or comments should be submitted by 3:00 PM EST on March 22, 2013 to allow for analysis and dissemination of responses in advance of the proposal due date. Late questions or comments are not guaranteed a response prior to the proposal due date.

**6. Attachment J.1.J, Government Furnished Equipment/Property/Material is revised to add 16 air filters (20"X 20"X1"). The updated Attachment J.1.J is provided with this amendment.**

**7. The closing submission due date for Part 2 (Price Volume) is April 8, 2013, 3:00 PM local time. The Solicitation, Standard Form 1442, Block 13, paragraph (a) is revised to read as follows:**

a. Sealed offers in original and 6 copies to perform the work required are due at the place specified in Item 8 by 1500 (hour) local time 04/08/2013 (date). If this is a sealed bid solicitation, offers will be publicly opened at that time. Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number, and the date and time offers are due.

**8. All other terms and conditions of NNK13457725R remain unchanged.**

