

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>		1. CONTRACT ID CODE	PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. 000002	3. EFFECTIVE DATE 06/28/2013	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (if applicable)	
6. ISSUED BY NASA/Marshall Space Flight Center Office of Procurement Marshall Space Flight Center AL 35812	CODE MSFC	7. ADMINISTERED BY (if other than Item 6) NASA/Marshall Space Flight Center Marshall Space Flight Center AL 35812	CODE MSFC	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(x) 9A. AMENDMENT OF SOLICITATION NO. NNM13ZPS002E	9B. DATED (SEE ITEM 11) 05/29/2013	
CODE		10A. MODIFICATION OF CONTRACT/ORDER NO.		
FACILITY CODE		10B. DATED (SEE ITEM 13)		

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

**12. ACCOUNTING AND APPROPRIATION DATA (if required)**

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

**14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)**

The purpose of this amendment to IFB NNM13ZPSC02E, Construct Replacement Building 4260, is to revise the answer to Question 16 in Amendment 1 dated June 27, 2013. In the last sentence of the answer to Question 16 "gypsum board" is revised to "abuse-resistant gypsum board." Question 16 and its answer now reads:

Question 16: Section 092900 Gypsum Board, Paragraph 2.3 Interior Gypsum Board. Paragraph C. Abuse-Resistant Gypsum Board. Where is this board required? Paragraph 2.4 Specialty Gypsum board. Paragraph A. Glass-Mat Interior Gypsum Board, subparagraph 1. Core: 5/8 inch, abuse resistant. Where is this board required?

Continued ...

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Brian A Speer
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED
	16B. UNITED STATES OF AMERICA Brian A. Speer (Signature of Contracting Officer)
	16C. DATE SIGNED June 28, 2013

**CONTINUATION SHEET**

REFERENCE NO. OF DOCUMENT BEING CONTINUED  
 NNM13ZPS002E/000002

PAGE OF  
 2 2

NAME OF OFFEROR OR CONTRACTOR

ITEM NO. (A)	SUPPLIES/SERVICES (B)	QUANTITY (C)	UNIT (D)	UNIT PRICE (E)	AMOUNT (F)
	<p>Answer: Abuse-resistant gypsum board is to be used for all interior gypsum board except at toilets and wet walls. Specialty gypsum board (glass-matt interior gypsum board) to be used at toilets and wet walls. All interior abuse-resistant gypsum board to be 8'-0" above finished floor.</p> <p>As a result of this amendment, the hour and date for bids is not extended. Bids are still due on Tuesday, July 2, 2013, at 2:00 P.M. local time at the Huntsville-Madison County Chamber of Commerce located at 25 Church Street, Huntsville, AL 35810.</p> <p>INCO TERMS 2: Destination</p>				