

| | | | | | |
|---|---|---|---------------------|--|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | 1. CONTRACT ID CODE | PAGE OF PAGES 1 2 | |
| 2. AMENDMENT/MODIFICATION NO. 1 | 3. EFFECTIVE DATE See Block 16C | 4. REQUISITION/PURCHASE REQ. NO. 4200520196 | | 5. PROJECT NO. (If applicable) 98894.2 | |
| 6. ISSUED BY CODE OP-ES | | 7. ADMINISTERED BY (If other than Item 6) CODE Same as block 6 | | | |
| John F. Kennedy Space Center, NASA Procurement Office, OP-ES Kennedy Space Center, FL 32899 | | | | | |

| | | | |
|--|---------------|---|--------------|
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and Zip Code) | | 9A. AMENDMENT OF SOLICITATION. | |
| Potential Contractors | | X | NNK14520196R |
| | | 10A. MODIFICATION OF CONTRACT/ORDER NO. | |
| | | 10B. DATED (SEE ITEM 13) | |
| CODE | FACILITY CODE | | |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

| |
|---|
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: |
| D. OTHER (Specify type of modification and authority) |

E. IMPORTANT: Contractor is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

- The purpose of **Amendment 1** is to:
- A.** Provide Government answers submitted by potential bidders.
 - B.** All other terms and conditions remain unchanged.

| | | | |
|---|------------------|--|------------------|
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | |
| 15B. CONTRACTOR/OFFEROR | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA | 16C. DATE SIGNED |
| (Signature of person authorized to sign) | | BY _____ (Signature of Contracting Officer) | |

NNK14520196R – Refurbish and Upgrade Water System, LC-39B, Phase 3, PCN: 98894.2

A.) ANSWERS TO BIDDERS QUESTIONS:

1. REFERENCE: Drawing M-101

QUESTION: Note 8. References Drawings 79K40019 Rev. V, 79K40071 Rev. M, and 80K58920 Rev. E. Please provide.

RESPONSE: 79K39811 Sheet M-101 Note 8 should have been removed. The drawings referenced in 79K39811 Sheet M-101 Note 8 do not affect bidding the work shown in 79K39811. There is not additional work scope or an alternative basis to be interpreted for performing the work scope more efficiently or cost effectively contained therein. The purpose of the note is to identify where some information used to generate 79K39811 originated. 79K40071 and 80K58920 are component lists (i.e. containing no drawing plans, details, or schematics) for the entire Pad B Fire Suppression/Freeze Protection Loop and LC 39 Pump Station, respectively, that were used to generate the specific component list on 79K39811 Sheet M-101. That is the information relevant to the work shown on 79K39811. 79K40019 is a valve and component schematic of the entire Pad B Fire Suppression/Freeze Protection Loop and LC 39 Pump Station. 79K40019 references the find numbers used in 79K40071 and 80K58920 (i.e. intended for component repair and replacement traceability). Portions of 79K40019 were used to generate the schematics shown on certain sheets of 79K39811. Where used in 79K39811, those schematics refer back to find numbers in the component list on 79K39811 Sheet M-101 for components to be replaced within the work scope of 79K39811. Therefore, all of the relevant information from these drawings is contained in 79K39811.

B.) ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED